



Declaration of Conformity  
NO.:ES111221120S

Product: Grid-Tied photovoltaic inverter  
Model Name: SP10000 Premium

is herewith confirmed to comply with the requirements set out in accordance with DIN V VDE V 0126-1-1:2006-02 and DIN V VDE V 0126-1-1/A1:2012-02 for photovoltaic systems with a three parallel coupling via an inverter in the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverter. This serves as a replacement for the disconnection device with insulating function which the distribution network provider can access at any time.

Applied rules and standards:

DIN V VDE V 0126-1-1(VDE V 0126-1-1)  
DIN V VDE V 0126-1-1/A1(VDE V 0126-1-1/A1):2012-02

The following manufacturer is responsible for this declaration:

Company Name: OPTI International Corporation  
Company Address: 7F., No. 192, Liancheng Rd., Zhonghe Dist.,  
New Taipei City 235, Taiwan

Name: Marcos Huang  
Position: General Manager  
Place: Taipei, Taiwan  
Date: November 3, 2014

